



Laboratory Report

Champlain Valley Edu Services 200674
1585 Military Turnpike
Plattsburgh, NY 12901

Atten: Stephanie Trombly

PROJECT: Lead in School Taps, CVES Main
WORK ORDER: **1609-21832**
DATE RECEIVED: September 26, 2016
DATE REPORTED: October 11, 2016
SAMPLER: Jerry B/ Ken K

Enclosed please find the results of the analyses performed for the samples referenced on the attached chain of custody located at the end of this report.

The column labeled Lab/Tech in the accompanying report denotes the laboratory facility where the testing was performed and the technician who conducted the assay. A "W" designates the Williston, VT lab under NELAC certification ELAP 11263; "R" designates the Lebanon, NH facility under certification NH 2037 and "N" the Plattsburgh, NY lab under certification ELAP 11892. "Sub" indicates the testing was performed by a subcontracted laboratory. The accreditation status of the subcontracted lab is referenced in the corresponding NELAC and Qual fields.

This NELAC column also denotes the accreditation status of each laboratory for each reported parameter. "A" indicates the referenced laboratory is NELAC accredited for the parameter reported. "N" indicates the laboratory is not accredited. "U" indicates that NELAC does not offer accreditation for that parameter in that specific matrix. Test results denoted with an "A" meet all National Environmental Laboratory Accreditation Program requirements except where denoted by pertinent data qualifiers. Test results are representative of the samples as they were received at the laboratory.

Endyne, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose.

Reviewed by:

Christina A Lafountain
Laboratory Director Plattsburgh, NY

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, CVES Main

WORK ORDER: **1609-21832**
DATE RECEIVED: 9/26/16

001	Site: 4270	Stagnant:	15.88 Hrs	Date Sampled:	9/24/16	Time: 1:02	
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.011	mg/L	SM 3113B-04	10/1/16	W RJL	A	
002	Site: 4260	Stagnant:	14.03 Hrs	Date Sampled:	9/24/16	Time: 1:03	
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.020	mg/L	SM 3113B-04	10/1/16	W RJL	A	
003	Site: 4250	Stagnant:	9.48 Hrs	Date Sampled:	9/24/16	Time: 1:04	
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.001	mg/L	SM 3113B-04	10/1/16	W RJL	A	
004	Site: 4010	Stagnant:	10.35 Hrs	Date Sampled:	9/24/16	Time: 0:50	
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.001	mg/L	SM 3113B-04	10/1/16	W RJL	A	
005	Site: 4130 B.S. R	Stagnant:	10.33 Hrs	Date Sampled:	9/24/16	Time: 1:05	
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.001	mg/L	SM 3113B-04	10/1/16	W RJL	A	
006	Site: 4130 B.S. L	Stagnant:	10.47 Hrs	Date Sampled:	9/24/16	Time: 1:06	
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.001	mg/L	SM 3113B-04	10/1/16	W RJL	A	
007	Site: 4220 KS R	Stagnant:	10.10 Hrs	Date Sampled:	9/24/16	Time: 1:07	
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.001	mg/L	SM 3113B-04	10/1/16	W RJL	A	
008	Site: 4220 BS L	Stagnant:	12.47 Hrs	Date Sampled:	9/24/16	Time: 1:08	
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.001	mg/L	SM 3113B-04	10/1/16	W RJL	A	
009	Site: 4020 K Sink	Stagnant:	10.95 Hrs	Date Sampled:	9/24/16	Time: 0:57	
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.002	mg/L	SM 3113B-04	10/1/16	W RJL	A	
010	Site: 4210 KS	Stagnant:	10.50 Hrs	Date Sampled:	9/24/16	Time: 1:10	
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>

Laboratory Report

CLIENT: Champlain Valley Edu Services
 PROJECT: Lead in School Taps, CVES Main

WORK ORDER: **1609-21832**
 DATE RECEIVED: 9/26/16

Lead, Total 0.001 mg/L SM 3113B-04 10/1/16 W RJL A

011	Site: 4210 BS				Stagnant:	15.30 Hrs	Date Sampled:	9/24/16	Time: 1:11
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.002	mg/L	SM 3113B-04		10/1/16	W RJL	A	

012	Site: 4030 KS				Stagnant:	10.12 Hrs	Date Sampled:	9/24/16	Time: 0:52
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.001	mg/L	SM 3113B-04		10/2/16	W RJL	A	

013	Site: 4030 BS				Stagnant:	10.12 Hrs	Date Sampled:	9/24/16	Time: 0:52
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	< 0.001	mg/L	SM 3113B-04		10/2/16	W RJL	A	

014	Site: 4200 KS				Stagnant:	10.95 Hrs	Date Sampled:	9/24/16	Time: 1:12
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.002	mg/L	SM 3113B-04		10/2/16	W RJL	A	

015	Site: 4200 BS				Stagnant:	11.68 Hrs	Date Sampled:	9/24/16	Time: 1:11
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	< 0.001	mg/L	SM 3113B-04		10/2/16	W RJL	A	

016	Site: 4050 KS				Stagnant:	10.72 Hrs	Date Sampled:	9/24/16	Time: 0:53
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.007	mg/L	SM 3113B-04		10/2/16	W RJL	A	

017	Site: 4050 BS				Stagnant:	11.57 Hrs	Date Sampled:	9/24/16	Time: 0:54
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.013	mg/L	SM 3113B-04		10/2/16	W RJL	A	

018	Site: 4190 KS				Stagnant:	10.72 Hrs	Date Sampled:	9/24/16	Time: 1:13
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.002	mg/L	SM 3113B-04		10/2/16	W RJL	A	

019	Site: 4190 BS				Stagnant:	11.02 Hrs	Date Sampled:	9/24/16	Time: 1:14
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	< 0.001	mg/L	SM 3113B-04		10/2/16	W RJL	A	

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, CVES Main

WORK ORDER: **1609-21832**
DATE RECEIVED: 9/26/16

020 Site: 4180 KS Stagnant: 10.83 Hrs Date Sampled: 9/24/16 Time: 1:15

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/2/16	W RJL	A	

021 Site: 4180 BS Stagnant: 10.28 Hrs Date Sampled: 9/24/16 Time: 1:16

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/2/16	W RJL	A	

022 Site: 4170 KS Stagnant: 10.60 Hrs Date Sampled: 9/24/16 Time: 1:17

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/2/16	W RJL	A	

023 Site: 4170 BS Stagnant: 11.85 Hrs Date Sampled: 9/24/16 Time: 1:18

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.001	mg/L	SM 3113B-04	10/2/16	W RJL	A	

024 Site: 4160 KS Stagnant: 12.57 Hrs Date Sampled: 9/24/16 Time: 1:19

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.003	mg/L	SM 3113B-04	10/2/16	W RJL	A	

025 Site: 4160 BS Stagnant: 10.62 Hrs Date Sampled: 9/24/16 Time: 1:20

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/2/16	W RJL	A	

026 Site: 4150 Stagnant: 10.83 Hrs Date Sampled: 9/24/16 Time: 1:22

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/2/16	W RJL	A	

027 Site: 4420 Stagnant: 10.58 Hrs Date Sampled: 9/24/16 Time: 0:43

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/2/16	W RJL	A	

028 Site: 4450 Stagnant: 10.27 Hrs Date Sampled: 9/24/16 Time: 0:46

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.003	mg/L	SM 3113B-04	10/2/16	W RJL	A	

029 Site: 4410 Stagnant: 10.07 Hrs Date Sampled: 9/24/16 Time: 0:44

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
-----------	--------	-------	--------	---------------	----------	-------	-------

Laboratory Report

CLIENT: Champlain Valley Edu Services
 PROJECT: Lead in School Taps, CVES Main

WORK ORDER: **1609-21832**

DATE RECEIVED: 9/26/16

Lead, Total 0.004 mg/L SM 3113B-04 10/2/16 W RJL A

030 Site: 4460 Stagnant: 10.07 Hrs Date Sampled: 9/24/16 Time: 0:47

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.003	mg/L	SM 3113B-04	10/2/16	W RJL	A	

031 Site: 4470 Stagnant: 9.15 Hrs Date Sampled: 9/24/16 Time: 0:49

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.017	mg/L	SM 3113B-04	10/2/16	W RJL	A	

032 Site: 4480 Stagnant: 10.77 Hrs Date Sampled: 9/24/16 Time: 0:51

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.004	mg/L	SM 3113B-04	10/2/16	W RJL	A	

033 Site: 4390 Stagnant: 10.25 Hrs Date Sampled: 9/24/16 Time: 0:45

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/2/16	W RJL	A	

034 Site: 4380 KS Stagnant: 10.10 Hrs Date Sampled: 9/24/16 Time: 0:46

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.003	mg/L	SM 3113B-04	10/2/16	W RJL	A	

035 Site: 4380 BS Stagnant: 13.62 Hrs Date Sampled: 9/24/16 Time: 0:47

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/2/16	W RJL	A	

036 Site: Speech Stagnant: 9.73 Hrs Date Sampled: 9/24/16 Time: 0:44

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/2/16	W RJL	A	

037 Site: 4360 KS Stagnant: 9.53 Hrs Date Sampled: 9/24/16 Time: 0:48

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/2/16	W RJL	A	

038 Site: 4360 BS Stagnant: 10.37 Hrs Date Sampled: 9/24/16 Time: 0:49

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.001	mg/L	SM 3113B-04	10/2/16	W RJL	A	

Laboratory Report

CLIENT: Champlain Valley Edu Services
 PROJECT: Lead in School Taps, CVES Main

WORK ORDER: **1609-21832**
 DATE RECEIVED: 9/26/16

039	Site: 4350 KS				Stagnant:	13.58 Hrs	Date Sampled:	9/24/16	Time: 0:50
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.009	mg/L	SM 3113B-04	10/2/16	W RJL	A		
040	Site: 4350 BS				Stagnant:	11.83 Hrs	Date Sampled:	9/24/16	Time: 0:51
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	< 0.001	mg/L	SM 3113B-04	10/2/16	W RJL	A		
041	Site: 4340				Stagnant:	15.07 Hrs	Date Sampled:	9/24/16	Time: 0:52
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	< 0.001	mg/L	SM 3113B-04	10/2/16	W RJL	A		
042	Site: 4330 KS				Stagnant:	12.87 Hrs	Date Sampled:	9/24/16	Time: 0:53
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.014	mg/L	SM 3113B-04	10/2/16	W RJL	A		
043	Site: 4330 BS				Stagnant:	12.35 Hrs	Date Sampled:	9/24/16	Time: 0:54
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.002	mg/L	SM 3113B-04	10/2/16	W RJL	A		
044	Site: 4320 KS				Stagnant:	10.25 Hrs	Date Sampled:	9/24/16	Time: 0:55
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.002	mg/L	SM 3113B-04	10/2/16	W RJL	A		
045	Site: 4320 BS				Stagnant:	10.08 Hrs	Date Sampled:	9/24/16	Time: 0:56
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	< 0.001	mg/L	SM 3113B-04	10/2/16	W RJL	A		
046	Site: 4310				Stagnant:	9.55 Hrs	Date Sampled:	9/24/16	Time: 0:57
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	< 0.001	mg/L	SM 3113B-04	10/2/16	W RJL	A		
047	Site: 4300 KS				Stagnant:	10.27 Hrs	Date Sampled:	9/24/16	Time: 1:01
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.004	mg/L	SM 3113B-04	10/2/16	W RJL	A		
048	Site: 4300 BS				Stagnant:	10.50 Hrs	Date Sampled:	9/24/16	Time: 1:00
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	

Laboratory Report

CLIENT: Champlain Valley Edu Services
 PROJECT: Lead in School Taps, CVES Main

WORK ORDER: **1609-21832**
 DATE RECEIVED: 9/26/16

Lead, Total 0.001 mg/L SM 3113B-04 10/2/16 W RJL A

049 Site: 3070 Stagnant: 10.25 Hrs Date Sampled: 9/24/16 Time: 0:30

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.034	mg/L	SM 3113B-04	10/2/16	W RJL	A	

050 Site: 3070 Stagnant: 10.10 Hrs Date Sampled: 9/24/16 Time: 0:31

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.018	mg/L	SM 3113B-04	10/2/16	W RJL	A	

051 Site: 3070 Ksink Stagnant: 9.87 Hrs Date Sampled: 9/24/16 Time: 0:32

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.006	mg/L	SM 3113B-04	10/2/16	W RJL	A	

052 Site: 3260 ksink Stagnant: 12.50 Hrs Date Sampled: 9/24/16 Time: 0:28

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/2/16	W RJL	A	

053 Site: 3260 teacher sink Stagnant: 14.08 Hrs Date Sampled: 9/24/16 Time: 0:26

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.013	mg/L	SM 3113B-04	10/2/16	W RJL	A	

054 Site: 3260 back wall s Stagnant: 12.40 Hrs Date Sampled: 9/24/16 Time: 0:27

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.001	mg/L	SM 3113B-04	10/2/16	W RJL	A	

055 Site: 3080 Stagnant: 9.75 Hrs Date Sampled: 9/24/16 Time: 0:35

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.009	mg/L	SM 3113B-04	10/2/16	W RJL	A	

056 Site: 3080 Stagnant: 9.60 Hrs Date Sampled: 9/24/16 Time: 0:36

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.008	mg/L	SM 3113B-04	10/2/16	W RJL	A	

057 Site: 3250 Stagnant: 10.80 Hrs Date Sampled: 9/24/16 Time: 0:28

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.030	mg/L	SM 3113B-04	10/2/16	W RJL	A	

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, CVES Main

WORK ORDER: **1609-21832**
DATE RECEIVED: 9/26/16

058	Site: 3240				Stagnant:	9.57 Hrs	Date Sampled:	9/24/16	Time: 0:29
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.012	mg/L	SM 3113B-04	10/2/16	W RJL	A		
059	Site: 3231 ks				Stagnant:	9.92 Hrs	Date Sampled:	9/24/16	Time: 0:30
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.005	mg/L	SM 3113B-04	10/2/16	W RJL	A		
060	Site: 3231 RR				Stagnant:	15.28 Hrs	Date Sampled:	9/24/16	Time: 0:31
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.011	mg/L	SM 3113B-04	10/2/16	W RJL	A		
061	Site: 3230 RR				Stagnant:	14.47 Hrs	Date Sampled:	9/24/16	Time: 0:32
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.006	mg/L	SM 3113B-04	10/2/16	W RJL	A		
062	Site: 3230 ksink				Stagnant:	12.80 Hrs	Date Sampled:	9/24/16	Time: 0:33
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.002	mg/L	SM 3113B-04	10/2/16	W RJL	A		
063	Site: 3230 D Fou				Stagnant:	12.52 Hrs	Date Sampled:	9/24/16	Time: 0:34
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.002	mg/L	SM 3113B-04	10/2/16	W RJL	A		
064	Site: 3100 sink R				Stagnant:	9.70 Hrs	Date Sampled:	9/24/16	Time: 0:38
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.007	mg/L	SM 3113B-04	10/2/16	W RJL	A		
065	Site: 3100 Sink L				Stagnant:	9.95 Hrs	Date Sampled:	9/24/16	Time: 0:38
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.003	mg/L	SM 3113B-04	10/2/16	W RJL	A		
066	Site: 3100 BR				Stagnant:	9.63 Hrs	Date Sampled:	9/24/16	Time: 0:39
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
	Lead, Total	0.019	mg/L	SM 3113B-04	10/2/16	W RJL	A		
067	Site: 3212 KS				Stagnant:	9.07 Hrs	Date Sampled:	9/24/16	Time: 0:36
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	

Laboratory Report

CLIENT: Champlain Valley Edu Services
 PROJECT: Lead in School Taps, CVES Main

WORK ORDER: **1609-21832**
 DATE RECEIVED: 9/26/16

Lead, Total 0.005 mg/L SM 3113B-04 10/2/16 W RJL A

068 Site: 3212 BS Stagnant: 9.07 Hrs Date Sampled: 9/24/16 Time: 0:37

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.011	mg/L	SM 3113B-04	10/2/16	W RJL	A	

069 Site: 3150 Stagnant: 10.17 Hrs Date Sampled: 9/24/16 Time: 0:40

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.032	mg/L	SM 3113B-04	10/2/16	W RJL	A	

070 Site: 3200 W sink Stagnant: 9.30 Hrs Date Sampled: 9/24/16 Time: 0:38

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.013	mg/L	SM 3113B-04	10/2/16	W RJL	A	

071 Site: 3190 W sink Stagnant: 9.23 Hrs Date Sampled: 9/24/16 Time: 0:39

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.010	mg/L	SM 3113B-04	10/2/16	W RJL	A	

072 Site: Not Sampled Stagnant: 0.00 Hrs Date Sampled: 9/24/16 Time: 0:00

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
No analysis							

073 Site: 3110 ksink Stagnant: 10.67 Hrs Date Sampled: 9/24/16 Time: 0:40

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.007	mg/L	SM 3113B-04	10/2/16	W RJL	A	

074 Site: 3140 ksink Stagnant: 10.52 Hrs Date Sampled: 9/24/16 Time: 0:41

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.011	mg/L	SM 3113B-04	10/2/16	W RJL	A	

075 Site: 3130 ksink Stagnant: 10.52 Hrs Date Sampled: 9/24/16 Time: 0:41

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.010	mg/L	SM 3113B-04	10/2/16	W RJL	A	

076 Site: 3130 BR sink Stagnant: 10.20 Hrs Date Sampled: 9/24/16 Time: 0:42

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.008	mg/L	SM 3113B-04	10/3/16	W FAA	A	

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, CVES Main

WORK ORDER: **1609-21832**
DATE RECEIVED: 9/26/16

077 Site: 3120 ksink Stagnant: 10.47 Hrs Date Sampled: 9/24/16 Time: 0:43

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.015	mg/L	SM 3113B-04	10/3/16	W FAA	A	

078 Site: 3180 Stagnant: 14.35 Hrs Date Sampled: 9/24/16 Time: 0:37

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.012	mg/L	SM 3113B-04	10/3/16	W FAA	A	

079 Site: 3160 R sink Stagnant: 13.43 Hrs Date Sampled: 9/24/16 Time: 0:38

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.017	mg/L	SM 3113B-04	10/3/16	W FAA	A	

080 Site: 3160 L Sink Stagnant: 12.67 Hrs Date Sampled: 9/24/16 Time: 0:39

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.006	mg/L	SM 3113B-04	10/3/16	W FAA	A	

081 Site: Not Sampled Stagnant: 0.00 Hrs Date Sampled: 9/24/16 Time: 0:00

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
-----------	--------	-------	--------	---------------	----------	-------	-------

No analysis

082 Site: 4000 Stagnant: 10.18 Hrs Date Sampled: 9/24/16 Time: 0:41

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.003	mg/L	SM 3113B-04	10/3/16	W FAA	A	

083 Site: 2080 Stagnant: 9.07 Hrs Date Sampled: 9/24/16 Time: 0:04

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.010	mg/L	SM 3113B-04	10/3/16	W FAA	A	

084 Site: 2090 DF Stagnant: 11.22 Hrs Date Sampled: 9/24/16 Time: 0:03

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.001	mg/L	SM 3113B-04	10/3/16	W FAA	A	

085 Site: 2090 sink Stagnant: 14.35 Hrs Date Sampled: 9/24/16 Time: 0:00

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.003	mg/L	SM 3113B-04	10/3/16	W FAA	A	

086 Site: S&L R. Room R Stagnant: 10.88 Hrs Date Sampled: 9/24/16 Time: 0:06

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
-----------	--------	-------	--------	---------------	----------	-------	-------

Laboratory Report

CLIENT: Champlain Valley Edu Services
 PROJECT: Lead in School Taps, CVES Main
 Lead, Total 0.004 mg/L

WORK ORDER: **1609-21832**
 DATE RECEIVED: 9/26/16
 10/3/16 W FAA A

087 Site: Not Sampled Stagnant: 0.00 Hrs Date Sampled: 9/24/16 Time: 0:00

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
No analysis							

088 Site: 2110 D Fou Lobby Stagnant: 14.93 Hrs Date Sampled: 9/24/16 Time: 0:05

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/3/16	W FAA	A	

089 Site: Drinking F Stagnant: 10.32 Hrs Date Sampled: 9/24/16 Time: 0:25

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.004	mg/L	SM 3113B-04	10/3/16	W FAA	A	

090 Site: DF Office Sp Ed Stagnant: 10.22 Hrs Date Sampled: 9/24/16 Time: 0:58

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.001	mg/L	SM 3113B-04	10/3/16	W FAA	A	

091 Site: 2120 DF Stagnant: 9.28 Hrs Date Sampled: 9/24/16 Time: 0:05

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.003	mg/L	SM 3113B-04	10/3/16	W FAA	A	

092 Site: 2010 DF Stagnant: 9.18 Hrs Date Sampled: 9/24/16 Time: 0:11

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.001	mg/L	SM 3113B-04	10/3/16	W FAA	A	

093 Site: 1000 Sink SPA Stagnant: 10.23 Hrs Date Sampled: 9/24/16 Time: 0:14

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/3/16	W FAA	A	

094 Site: 1000 Sink nails Stagnant: 10.15 Hrs Date Sampled: 9/24/16 Time: 0:14

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.003	mg/L	SM 3113B-04	10/3/16	W FAA	A	

095 Site: 1000 Sink disp R Stagnant: 9.40 Hrs Date Sampled: 9/24/16 Time: 0:14

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.003	mg/L	SM 3113B-04	10/3/16	W FAA	A	

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, CVES Main

WORK ORDER: **1609-21832**
DATE RECEIVED: 9/26/16

096	Site: 1000 sink disp L			Stagnant:	9.23 Hrs	Date Sampled:	9/24/16	Time: 0:14
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.003	mg/L	SM 3113B-04	10/3/16	W FAA	A	
097	Site: 1040 BR Sink			Stagnant:	10.42 Hrs	Date Sampled:	9/24/16	Time: 0:25
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.011	mg/L	SM 3113B-04	10/3/16	W FAA	A	
098	Site: 1040 R sink			Stagnant:	9.92 Hrs	Date Sampled:	9/24/16	Time: 0:25
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.007	mg/L	SM 3113B-04	10/3/16	W FAA	A	
099	Site: 1040 C sink			Stagnant:	9.92 Hrs	Date Sampled:	9/24/16	Time: 0:25
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.006	mg/L	SM 3113B-04	10/3/16	W FAA	A	
100	Site: 1040 L sink			Stagnant:	9.92 Hrs	Date Sampled:	9/24/16	Time: 0:25
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.005	mg/L	SM 3113B-04	10/3/16	W FAA	A	
101	Site: 1040 K sink			Stagnant:	9.92 Hrs	Date Sampled:	9/24/16	Time: 0:25
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.006	mg/L	SM 3113B-04	10/3/16	W FAA	A	
102	Site: 1050 R sink			Stagnant:	9.63 Hrs	Date Sampled:	9/24/16	Time: 0:23
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	< 0.001	mg/L	SM 3113B-04	10/3/16	W FAA	A	
103	Site: 1050 L sink			Stagnant:	9.65 Hrs	Date Sampled:	9/24/16	Time: 0:24
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.002	mg/L	SM 3113B-04	10/3/16	W FAA	A	
104	Site: 1060 DF			Stagnant:	9.25 Hrs	Date Sampled:	9/24/16	Time: 0:20
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.002	mg/L	SM 3113B-04	10/3/16	W FAA	A	
105	Site: 1060 Sink			Stagnant:	9.10 Hrs	Date Sampled:	9/24/16	Time: 0:21
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>

Laboratory Report

CLIENT: Champlain Valley Edu Services
 PROJECT: Lead in School Taps, CVES Main
 Lead, Total 0.001 mg/L

WORK ORDER: 1609-21832
 DATE RECEIVED: 9/26/16
 10/6/16 W FAA A

106 Site: Not Sampled Stagnant: 0.00 Hrs Date Sampled: 9/24/16 Time: 0:00

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
No analysis							

107 Site: 1070 SL sink Stagnant: 10.23 Hrs Date Sampled: 9/24/16 Time: 0:14

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.013	mg/L	SM 3113B-04	10/6/16	W FAA	A	

108 Site: 1070 Veg R Stagnant: 10.25 Hrs Date Sampled: 9/24/16 Time: 0:15

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.003	mg/L	SM 3113B-04	10/6/16	W FAA	A	

109 Site: 1070 Veg L Stagnant: 10.27 Hrs Date Sampled: 9/24/16 Time: 0:16

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.012	mg/L	SM 3113B-04	10/6/16	W FAA	A	

110 Site: 1070 Sink back wall Stagnant: 9.55 Hrs Date Sampled: 9/24/16 Time: 0:18

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.016	mg/L	SM 3113B-04	10/6/16	W FAA	A	

111 Site: 1070 Stagnant: 13.15 Hrs Date Sampled: 9/24/16 Time: 0:19

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.013	mg/L	SM 3113B-04	10/6/16	W FAA	A	

112 Site: 3010 W BR Sink Stagnant: 8.92 Hrs Date Sampled: 9/24/16 Time: 0:10

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.006	mg/L	SM 3113B-04	10/6/16	W FAA	A	

113 Site: 3010 M BR Sink Stagnant: 9.72 Hrs Date Sampled: 9/24/16 Time: 0:10

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.009	mg/L	SM 3113B-04	10/6/16	W FAA	A	

114 Site: 3010 Sink Stagnant: 10.17 Hrs Date Sampled: 9/24/16 Time: 0:10

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.007	mg/L	SM 3113B-04	10/6/16	W FAA	A	

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, CVES Main

WORK ORDER: **1609-21832**
DATE RECEIVED: 9/26/16

115	Site: 4100				Stagnant:	11.33 Hrs	Date Sampled:	9/24/16	Time: 1:30
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.006	mg/L	SM 3113B-04		10/6/16	W FAA	A	
116	Site: 4060 ksink				Stagnant:	10.52 Hrs	Date Sampled:	9/24/16	Time: 0:55
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.002	mg/L	SM 3113B-04		10/6/16	W FAA	A	
117	Site: 4090 B sink				Stagnant:	11.00 Hrs	Date Sampled:	9/24/16	Time: 1:10
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.001	mg/L	SM 3113B-04		10/6/16	W FAA	A	
118	Site: 4070 servline				Stagnant:	12.42 Hrs	Date Sampled:	9/24/16	Time: 1:35
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.011	mg/L	SM 3113B-04		10/6/16	W FAA	A	
119	Site: 4070 Ice				Stagnant:	0.00 Hrs	Date Sampled:	9/24/16	Time: 0:50
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	< 0.0010	mg/L	SM 3113B-04		10/7/16	W MGT	A	
120	Site: 4070 Hand Sink				Stagnant:	13.10 Hrs	Date Sampled:	9/24/16	Time: 1:36
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.0111	mg/L	SM 3113B-04		10/7/16	W MGT	A	
121	Site: 4070 L sink				Stagnant:	12.53 Hrs	Date Sampled:	9/24/16	Time: 1:37
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.0199	mg/L	SM 3113B-04		10/7/16	W MGT	A	
122	Site: 4070 R sink				Stagnant:	12.63 Hrs	Date Sampled:	9/24/16	Time: 1:38
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.0089	mg/L	SM 3113B-04		10/7/16	W MGT	A	
123	Site: 4070 Sink by stove				Stagnant:	12.45 Hrs	Date Sampled:	9/24/16	Time: 1:39
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
	Lead, Total	0.0062	mg/L	SM 3113B-04		10/7/16	W MGT	A	
124	Site: S Law RR Left				Stagnant:	11.88 Hrs	Date Sampled:	9/24/16	Time: 0:06
	<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>		<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>

Laboratory Report

CLIENT: Champlain Valley Edu Services
 PROJECT: Lead in School Taps, CVES Main

WORK ORDER: **1609-21832**
 DATE RECEIVED: 9/26/16

Lead, Total 0.0069 mg/L SM 3113B-04 10/7/16 W MGT A

125 Site: Boys Handi CV-R sink Stagnant: 8.72 Hrs Date Sampled: 9/24/16 Time: 0:27

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0078	mg/L	SM 3113B-04	10/7/16	W MGT	A	

126 Site: Girls Handi CV-L sink Stagnant: 8.72 Hrs Date Sampled: 9/24/16 Time: 0:27

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0100	mg/L	SM 3113B-04	10/7/16	W MGT	A	

127 Site: Girls Handi CV-L sink Stagnant: 8.72 Hrs Date Sampled: 9/24/16 Time: 0:28

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0196	mg/L	SM 3113B-04	10/7/16	W MGT	A	

128 Site: Not Sampled Stagnant: 0.00 Hrs Date Sampled: 9/24/16 Time: 0:00

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
No analysis							

129 Site: D foun Pool area Stagnant: 10.00 Hrs Date Sampled: 9/24/16 Time: 1:00

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

130 Site: 4120 BRL Stagnant: 10.08 Hrs Date Sampled: 9/24/16 Time: 1:05

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

131 Site: 4120 BRR Stagnant: 10.08 Hrs Date Sampled: 9/24/16 Time: 1:05

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

132 Site: CV-TEC ICE Stagnant: 0.00 Hrs Date Sampled: 9/24/16 Time: 2:00

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	SM 3113B-04	10/7/16	W MGT	A	

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.



Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

26 Oct 16

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: Champlain Valley Ed Services
(Main)

Account #: 200674

SAMPLE SUPPLY INFORMATION

Email Address:

PWS # Town of Plattsburgh

Contact Person: Jerry Brooks

Project Name BOCES

Collection Address: 1585 Military Turnpike

Phone: 518-561-0100 XT 228

3T - Lead in Schools

PO #

City: Plattsburgh State: NY Zip: 12901

Pag 1 of 5

Collector's Name: Jerry B / Kim K

SAMPLE MATRIX CODES

DW=drinking water SW=Surface Water
WW=waste water SD=solid
MW=monitoring well SO=soil
HW=hazardous waste SL=sludge

Compliance? Yes
Initial Testing
or
Repeat Testing

TURNAROUND TIME REQUESTED

Standard (2-4 weeks)

Sample ID / Collection Site	Date/Time ^{AM}	Bottle Type / Volume	M a t r i x	Preservation	First Draw (Y)	Flushed Line (Y)	Total Lead	Analysis Requested:	Water Last Used (Date / Time)	Lab Use Sample #
1 <u>4270</u>	<u>9/24/16 1:02</u>	250mL, P	DW	*	<u>Y</u>	<u>N</u>	X		<u>9/23/16 9:09^A</u>	001
2 <u>4260</u>	<u>1:03</u>	250mL, P	DW	*			X		<u>11:01^A</u>	002
3 <u>4250</u>	<u>1:04</u>	250mL, P	DW	*			X		<u>3:35 P</u>	003
4 <u>4010 KS</u>	<u>12:50</u>	250mL, P	DW	*			X		<u>2:29 P</u>	004
5 <u>4130 B.S R</u>	<u>1:05</u>	250mL, P	DW	*			X		<u>2:45^{PM}</u>	005
6 <u>4130 B.S L</u>	<u>1:06</u>	250mL, P	DW	*			X		<u>2:38 P</u>	006
7 <u>4220 KS R</u>	<u>1:07</u>	250mL, P	DW	*			X		<u>3:01 P</u>	007
8 <u>4220 BS L</u>	<u>1:08</u>	250mL, P	DW	*			X		<u>12:40 P</u>	008
9 <u>4020 K sink</u>	<u>12:57</u>	250mL, P	DW	*			X		<u>2:00 P</u>	009
10 <u>4210 KS</u>	<u>1:10</u>	250mL, P	DW	*			X		<u>2:40 P</u>	010
11 <u>4210 BS</u>	<u>1:11</u>	250mL, P	DW	*			X		<u>9:53 A</u>	011
12 <u>4220 4030 KS</u>	<u>12:50</u>	250mL, P	DW	*	<u>Y</u>	<u>Y</u>	X		<u>2:45 P</u>	012

SAMPLE RECEIPT (Lab Use Only)

Date

Time

Sample Relinquished By (SIGN HERE)

Samples Received By

Samples Intact? YS

26 Sep 16

0839

JLB Jerry L Brooks

Filled to proper volume? YS

of Containers 127

JB
ENTERED

1609-21832



1609-21832

Champlain Valley Edu Services
Lead in School Taps, CUES Main

* Samples preserved with NHO3 to pH < 2 after receipt at the lab.

@ ~1245 on 26 Sep 16 by Ben G. (X)

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

OFFICE USE ONLY

Analysis Fee \$

X or A/R

Terms are net 30 days with

Payment Method ☐ Cash ☐ Check ☐ MC/Visa

☐ Money Order

Check, MO, Receipt #

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: Champlain Valley ED Services
(Main)

Account #: 200674

Collector's Name: ADD KENZAN

Page 2 of 5

Work Order # 21832

Sample ID / Collection Site	Date/Time	Bottle	M a t r i x	Pres	1st Draw	Flushed Line	Lead, Total	Water Last Used (date/ Time)	Sample #
13 4030 BS	9/24/12 12:52 AM	250mL, P	DW	*	Y	N	X	9/23/12 2:45 P	013
14 4200 KS	11/12	250mL, P	DW	*			X	2:15 P	014
15 4200 BS	11/11	250mL, P	DW	*			X	11:30 P	015
16 4050 KS	12:53	250mL, P	DW	*			X	2:10 P	016
17 4050 BS	12:54	250mL, P	DW	*			X	11:20 P	017
18 4190 KS	1:13	250mL, P	DW	*			X	2:30 P	018
19 4190 BS	1:14	250mL, P	DW	*			X	2:13 P	019
20 4180 KS	1:15	250mL, P	DW	*			X	2:25 P	020
21 4180 BS	1:16	250mL, P	DW	*			X	2:59 P	021
22 4170 KS	1:17	250mL, P	DW	*			X	2:41 P	022
23 4170 BS	1:18	250mL, P	DW	*			X	1:27 P	023
24 4160 KS	1:19	250mL, P	DW	*			X	12:45 P	024
25 4160 BS	1:20	250mL, P	DW	*			X	2:43 P	025
26 4150	1:22	250mL, P	DW	*			X	2:32 P	026
27 4420	12:43	250mL, P	DW	*			X	2:08 P	027
28 4450	12:46	250mL, P	DW	*			X	2:30 P	028
29 4410	12:44	250mL, P	DW	*			X	2:40 P	029
30 4460	12:47	250mL, P	DW	*			X	2:43 P	030
31 4470	12:49	250mL, P	DW	*			X	3:40 P	031
32 4480	12:51	250mL, P	DW	*			X	2:05 P	032
33 4390	12:45	250mL, P	DW	*			X	2:30 P	033
34 4380 KS	12:46	250mL, P	DW	*			X	2:40 P	034
35 4380 BS	12:47	250mL, P	DW	*			X	11:10 AM	035
36 Speech	12:44	250mL, P	DW	*			X	3:00 P	036
37 4360 KS	12:48	250mL, P	DW	*			X	3:16 P	037
38 4360 BS	12:49	250mL, P	DW	*			X	2:27 P	038
39 4350 KS	12:50	250mL, P	DW	*			X	11:15 AM	039
40 4350 BS	12:51	250mL, P	DW	*			X	1:01 P	040
41 4340	12:52	250mL, P	DW	*			X	9:48 A	041
42 4330 KS	12:53	250mL, P	DW	*			X	12:01 P	042
43 4330 BS	12:54	250mL, P	DW	*			X	12:33 P	043
44 4320 KS	12:55	250mL, P	DW	*			X	2:40 P	044
45 4320 BS	12:56	250mL, P	DW	*			X	2:51 P	045
46 4310	12:51	250mL, P	DW	*			X	3:24 P	046

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: Champlain Valley Ed Service
(main)

Account #: 200674

Collector's Name: Jerry Brooks / Ken Kezan

Page 3 of 5

Work Order #

21832

Sample ID / Collection Site	Date/Time ^{AM}	Bottle	M a t r i x	Pres	1st Draw	Flushed Line	Lead, Total	Water Last Used (date/ Time)	Sample #
47 4300 KS	9/24/16 1:01	250mL, P	DW	*	✓	N	X	9/23/16 2:45 P	047
48 4300 BS	1:00	250mL, P	DW	*			X	2:30 P	048
49 3070	12:30	250mL, P	DW	*			X	2:15 P	049
50 3070	12:31	250mL, P	DW	*			X	2:25 P	050
51 3070 K sink	12:32	250mL, P	DW	*			X	2:40 P	051
52 3260 K sink	12:28	250mL, P	DW	*			X	AM 11:58	052
53 3260 Teacher sink	12:26	250mL, P	DW	*			X	AM 10:21	053
54 3260 Back wall S	12:27	250mL, P	DW	*			X	P 12:03	054
55 3080	12:35	250mL, P	DW	*			X	P 2:50	055
56 3080	12:36	250mL, P	DW	*			X	P 3:00	056
57 3250	12:28	250mL, P	DW	*			X	P 1:40	057
58 3240	12:29	250mL, P	DW	*			X	P 2:55	058
59 3230 3231 KS	12:30	250mL, P	DW	*			X	P 2:35	059
60 3230 3231 RR	12:31	250mL, P	DW	*			X	A 9:54	060
61 3230 RR	12:32	250mL, P	DW	*			X	A 10:04	061
62 3230 K sink	12:33	250mL, P	DW	*			X	A 11:45	062
63 3230 D Fou	12:34	250mL, P	DW	*			X	P 12:03	063
64 3100 sink R	12:38	250mL, P	DW	*			X	P 2:56	064
65 3100 sink L	12:38	250mL, P	DW	*			X	P 2:41	065
66 3100 BR	12:39	250mL, P	DW	*			X	P 3:01	066
67 3212 KS	12:36	250mL, P	DW	*			X	P 3:32	067
68 3212 BS	12:37	250mL, P	DW	*			X	P 3:33	068
69 3230 3150	12:40	250mL, P	DW	*			X	P 2:30	069
70 3200 W sink	12:38	250mL, P	DW	*			X	P 3:20	070
71 3190 W sink	12:39	250mL, P	DW	*			X	P 3:25	071
72 3190 (Not Sampled)		250mL, P	DW	*			X		072
73 3110 K sink	12:40	250mL, P	DW	*			X	P 2:00	073
74 3140 K sink	12:41	250mL, P	DW	*			X	P 2:10	074
75 3130 K sink	12:42	250mL, P	DW	*			X	P 3:00	075
76 3130 BR sink	12:42	250mL, P	DW	*			X	P 2:30	076
77 3120 K sink	12:43	250mL, P	DW	*			X	P 2:15	077
78 3180	12:37	250mL, P	DW	*			X	10:16 AM	078
79 3160 R sink	12:38	250mL, P	DW	*			X	11:10 AM	079
80 3160 L sink	12:39	250mL, P	DW	*			X	11:59 AM	080

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: Champlain Valley Ed Service
(main)

Account #: 200 674

Collector's Name: Jerry Brooks / Ken Kezak

Page 4 of 5

Work Order # 21832

Sample ID / Collection Site	Date/Time ^{AM}	Bottle	M a t r i x	Pres	1st Draw	Flushed Line	Lead, Total	Water Last Used (date/ Time)	Sample #
81 Not Sampled	9/24/16	250mL, P	DW	*	Y	N	X	9/23/16	081
82 4000	12:41	250mL, P	DW	*			X	2:30 P	082
83 2080	12:04 AM	250mL, P	DW	*			X	3:00 PM	083
84 2090 DF	12:03	250mL, P	DW	*			X	12:50 P	084
85 2090 sink	12:00	250mL, P	DW	*			X	9:39 A	085
86 2090 SL R. Room R	12:06	250mL, P	DW	*			X	1:13 P	086
87 Not Sampled		250mL, P	DW	*			X		087
88 2110 DF Lobby	12:05	250mL, P	DW	*			X	9:09 AM	088
89 2020 DF Drinking F	12:25	250mL, P	DW	*			X	2:06 P	089
90 2020 DF DF Office 50.00	12:58	250mL, P	DW	*			X	2:45 P	090
91 2120 DF	12:05	250mL, P	DW	*			X	2:48 P	091
92 2010 DF	12:11	250mL, P	DW	*			X	3:00 P	092
93 1000 sink SPA	12:14	250mL, P	DW	*			X	2:00 P	093
94 1000 sink Nails	12:14	250mL, P	DW	*			X	2:05 P	094
95 1000 sink Disp R	12:14	250mL, P	DW	*			X	2:50 P	095
96 1000 sink Disp L	12:14	250mL, P	DW	*			X	3:00 P	096
97 1040 BR sink	12:25	250mL, P	DW	*			X	2:00 P	097
98 1040 R sink	12:25	250mL, P	DW	*			X	2:30 P	098
99 1040 C sink	12:25	250mL, P	DW	*			X	2:30 P	099
100 1040 L sink	12:25	250mL, P	DW	*			X	2:30 P	100
101 1040 K sink	12:25	250mL, P	DW	*			X	2:30 P	101
102 1050 R sink	12:23	250mL, P	DW	*			X	2:45	102
103 1050 L sink	12:24	250mL, P	DW	*			X	2:45	103
104 1060 DF	12:20	250mL, P	DW	*			X	3:05	104
105 1060 sink	12:21	250mL, P	DW	*			X	3:05	105
106 Not Sampled		250mL, P	DW	*			X		106
107 1070 SL sink	12:14	250mL, P	DW	*			X	2:00 P	107
108 1070 veg R	12:15	250mL, P	DW	*			X	2:00 P	108
109 1070 veg L	12:16	250mL, P	DW	*			X	2:00 P	109
110 1070 sink back wall	12:18	250mL, P	DW	*			X	2:45 P	110
111 1070	12:19	250mL, P	DW	*			X	11:10 A	111
112 3010 WBR sink	12:10	250mL, P	DW	*			X	2:15 P	112
113 3010 MBR sink	12:10	250mL, P	DW	*			X	2:27 P	113
114 3010 sink	12:10	250mL, P	DW	*			X	2:00 P	114

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: Champlain Valley Ed Service
(main)

Account #: 200674

Collector's Name: Jerry Brooks / Ken KERRAN

Page 5 of 5

Work Order # 21832

Sample ID / Collection Site	Date/Time ^{AM}	Bottle	M a t r i x	Pres	1st Draw	Flushed Line	Lead, Total	Water Last Used (date/ Time)	Sample #
115 4100	4/24/16 1:30	250mL, P	DW	*	Y	N	X	4/23/16 2:10 P	115
116 4060 K Sink	12:55	250mL, P	DW	*			X	2:24 P	116
117 4090 B Sink	1:10	250mL, P	DW	*			X	2:10 P	117
118 4070 Sewerline	1:35	250mL, P	DW	*			X	1:10 P	118
119 4070 ICE	2:50	250mL, P	DW	*			X	ICE 8A	119
120 4070 Hand sink	1:36	250mL, P	DW	*			X	12:30 P	120
121 4070 L Sink	1:37	250mL, P	DW	*			X	1:05 P	121
122 4070 R Sink	1:38	250mL, P	DW	*			X	1:00 P	122
123 4070 Sink by stove	1:39	250mL, P	DW	*			X	1:12 P	123
124 Sewer R.R. Left	12:00	250mL, P	DW	*			X	12:13 P	124
125 Boys Hand: CV TEL	12:27	250mL, P	DW	*			X	3:44 P	125
126 Girls Hand: CV- R Sink	12:27	250mL, P	DW	*			X	3:44 P	126
127 Girls Hand: CV- L Sink	12:28	250mL, P	DW	*			X	3:45 P	127
128 Not Sampled		250mL, P	DW	*			X		128
129 D Four Pool Area	1:00	250mL, P	DW	*			X	3:00 P	129
130 4120 BR L	1:05	250mL, P	DW	*			X	3:00 P	130
131 4120 BR R	1:05	250mL, P	DW	*			X	3:00 P	131
132 CV-TEL ICE	12:00	250mL, P	DW	*			X	ICE 8A	132
133		250mL, P	DW	*			X		133
134		250mL, P	DW	*			X		134
135		250mL, P	DW	*			X		135
136		250mL, P	DW	*			X		136
137		250mL, P	DW	*			X		137
138		250mL, P	DW	*			X		138
139		250mL, P	DW	*			X		139
140		250mL, P	DW	*			X		140
141		250mL, P	DW	*			X		141
142		250mL, P	DW	*			X		142
143		250mL, P	DW	*			X		143
144		250mL, P	DW	*			X		144
145		250mL, P	DW	*			X		145
146		250mL, P	DW	*			X		146
147		250mL, P	DW	*			X		147
148		250mL, P	DW	*			X		148