



Laboratory Report

Champlain Valley Edu Services 200674
1585 Military Turnpike
Plattsburgh, NY 12901

Atten: Stephanie Trombly

PROJECT: Lead in School Taps, PSC
WORK ORDER: **1609-21610**
DATE RECEIVED: September 22, 2016
DATE REPORTED: October 03, 2016
SAMPLER: Jerry Brooks

Enclosed please find the results of the analyses performed for the samples referenced on the attached chain of custody located at the end of this report.

The column labeled Lab/Tech in the accompanying report denotes the laboratory facility where the testing was performed and the technician who conducted the assay. A "W" designates the Williston, VT lab under NELAC certification ELAP 11263; "R" designates the Lebanon, NH facility under certification NH 2037 and "N" the Plattsburgh, NY lab under certification ELAP 11892. "Sub" indicates the testing was performed by a subcontracted laboratory. The accreditation status of the subcontracted lab is referenced in the corresponding NELAC and Qual fields.

This NELAC column also denotes the accreditation status of each laboratory for each reported parameter. "A" indicates the referenced laboratory is NELAC accredited for the parameter reported. "N" indicates the laboratory is not accredited. "U" indicates that NELAC does not offer accreditation for that parameter in that specific matrix. Test results denoted with an "A" meet all National Environmental Laboratory Accreditation Program requirements except where denoted by pertinent data qualifiers. Test results are representative of the samples as they were received at the laboratory.

Endyne, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose.

Reviewed by:

Christina A Lafountain
Laboratory Director Plattsburgh, NY

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, PSC

WORK ORDER: **1609-21610**
DATE RECEIVED: 9/22/16

001 Site: S. Hanger Boys R. Room R Stagnant: 9.75 Hrs Date Sampled: 9/22/16 Time: 6:42

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.003	mg/L	SM 3113B-04	10/1/16	W RJL	A	

002 Site: S. Hanger Boys R. Room L Stagnant: 9.78 Hrs Date Sampled: 9/22/16 Time: 6:43

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.003	mg/L	SM 3113B-04	10/1/16	W RJL	A	

003 Site: S. Hanger - Girls R. Room R Stagnant: 9.80 Hrs Date Sampled: 9/22/16 Time: 6:41

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/1/16	W RJL	A	

004 Site: S. Hanger - Girls R. Room L Stagnant: 9.77 Hrs Date Sampled: 9/22/16 Time: 6:40

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.009	mg/L	SM 3113B-04	10/1/16	W RJL	A	

005 Site: District Office R. Room Stagnant: 9.50 Hrs Date Sampled: 9/22/16 Time: 6:45

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/1/16	W RJL	A	

006 Site: Admin Kitchen Stagnant: 9.70 Hrs Date Sampled: 9/22/16 Time: 6:47

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.004	mg/L	SM 3113B-04	10/1/16	W RJL	A	

007 Site: Admin R. Room 1 Stagnant: 9.70 Hrs Date Sampled: 9/22/16 Time: 6:47

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/1/16	W RJL	A	

008 Site: Admin R. Room 2 Stagnant: 9.70 Hrs Date Sampled: 9/22/16 Time: 6:51

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.002	mg/L	SM 3113B-04	10/1/16	W RJL	A	

009 Site: N. Hanger Boys R. Room R Stagnant: 10.18 Hrs Date Sampled: 9/22/16 Time: 6:52

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.004	mg/L	SM 3113B-04	10/1/16	W RJL	A	

010 Site: N. Hanger Boys Room L Stagnant: 10.18 Hrs Date Sampled: 9/22/16 Time: 6:54

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
-----------	--------	-------	--------	---------------	----------	-------	-------

Laboratory Report

CLIENT:	Champlain Valley Edu Services	WORK ORDER:	1609-21610
PROJECT:	Lead in School Taps, PSC	DATE RECEIVED:	9/22/16
Lead, Total	0.003	mg/L	SM 3113B-04
			10/1/16
			W RJL
			A

011	Site: N. Hanger Girls Room R	Stagnant:	10.35 Hrs	Date Sampled:	9/22/16	Time:	6:56
-----	------------------------------	-----------	-----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.003	mg/L	SM 3113B-04	10/1/16	W RJL	A	

012	Site: N. Hanger Girls Room L	Stagnant:	10.35 Hrs	Date Sampled:	9/22/16	Time:	6:58
-----	------------------------------	-----------	-----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.007	mg/L	SM 3113B-04	10/1/16	W RJL	A	

Report Summary of Qualifiers and Notes

Sample -009 volume was filled to approximately 240 mL.

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY
Due Date: 2004/16

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: Champlain Valley Ed Services (SATELITE) Account #: 200674 PSE

Email Address: _____ PWS # Town of Plattsburgh

Contact Person: Jerry Brooks Project Name: _____ Collection Address: 518 Ruger St

Phone: 518-561-0100 XT 228 3T - Lead in Schools

PO # _____ City: Plattsburgh State: NY Zip: 12901

SAMPLE MATRIX CODES		Compliance? (Yes) Initial Testing or Repeat Testing	Bottle Type / Volume	Matrix	Preservation	First Draw (Y)	Flushed Line (Y)	Total Lead	Analysis Requested:		Lab Use Sample #
DW=drinking water	SW=Surface Water								Water Last Used (Date / Time) PM		
WW=waste water	SD=solid										
MW=monitoring well	SO=soil										
HW=hazardous waste	SL=sludge										
TURNAROUND TIME REQUESTED											
Standard (2-4 weeks)											
Sample ID / Collection Site	Date/Time AM										
1 S-Wanger Boys R-Room R	9/22/16 6:42 PM		250mL, P	DW	*	Y	N	X		9/21/16 8:57	001
2 S-Wanger Boys R-Room L	6:43		250mL, P	DW	*			X		8:56	002
3 S-Wanger - Girls R-Room R	6:44 (0641)		250mL, P	DW	*			X		8:53	003
4 S-Wanger - Girls R-Room L	6:40 AM		250mL, P	DW	*			X		8:54 AM	004
5 District office R-Room	6:45		250mL, P	DW	*			X		9:15	005
6 Admin Kitchen	6:47		250mL, P	DW	*			X		9:05	006
7 Admin R-Room 1	6:49		250mL, P	DW	*			X		9:08	007
8 Admin R-Room 2	6:51		250mL, P	DW	*			X		9:09	008
9 N-Wanger Boys Room R	6:52		250mL, P	DW	*			X		8:41	009
10 N-Wanger Boys Room L	6:54		250mL, P	DW	*			X		8:43	010
11 N-Wanger Girls Room R	6:56		250mL, P	DW	*			X		8:35	011
12 N-Wanger Girls Room L	6:58		250mL, P	DW	*			X		8:37	012


SAMPLE RECEIPT (Lab Use Only)	Date	Time	Sample Relinquished By (SIGN HERE)	Samples Received By
Samples Intact? <u>yes</u>	<u>22 Sept 16</u>	<u>10:18</u>	<u>[Signature]</u>	<u>[Signature]</u>
Filled to proper volume? <u>*1</u>				

of Containers 12

* Volume was just under 250ml equivalent 30ml

* Samples preserved with NHO3 to pH < 2 after receipt at the lab. 29 Sept 16

1609-21610



Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

OFFICE USE ONLY	Analysis Fee \$ <u>X</u> or A/R	Terms are net 30 days with an open, up to date account
	Payment Method <input type="checkbox"/> Cash <input type="checkbox"/> Check <input type="checkbox"/> MC/Visa <input type="checkbox"/> Money Order	Check, MO, Receipt # _____