



Laboratory Report

Champlain Valley Edu Services 200674
1585 Military Turnpike
Plattsburgh, NY 12901

Atten: Stephanie Trombly

PROJECT: Lead in School Taps,CVES MineV
WORK ORDER: **2106-16955**
DATE RECEIVED: June 16, 2021
DATE REPORTED: July 01, 2021
SAMPLER: Jerry Brooks

Enclosed please find the results of the analyses performed for the samples referenced on the attached chain of custody located at the end of this report.

The column labeled Lab/Tech in the accompanying report denotes the laboratory facility where the testing was performed and the technician who conducted the assay. A "W" designates the Williston, VT lab under NELAC certification ELAP 11263; "R" designates the Lebanon, NH facility under certification NH 2037 and "N" the Plattsburgh, NY lab under certification ELAP 11892. "Sub" indicates the testing was performed by a subcontracted laboratory. The accreditation status of the subcontracted lab is referenced in the corresponding NELAC and Qual fields.

This NELAC column also denotes the accreditation status of each laboratory for each reported parameter. "A" indicates the referenced laboratory is NELAC accredited for the parameter reported. "N" indicates the laboratory is not accredited. "U" indicates that NELAC does not offer accreditation for that parameter in that specific matrix. Test results denoted with an "A" meet all National Environmental Laboratory Accreditation Program requirements except where denoted by pertinent data qualifiers. Test results are representative of the samples as they were received at the laboratory.

Endyne, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose.

Reviewed by:

Christina A Lafountain
Laboratory Director Plattsburgh, NY

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps,CVES MineV

WORK ORDER: 2106-16955
DATE RECEIVED: 6/16/21

001	Site: 1080	Stagnant:	18.33 Hrs	Date Sampled:	6/16/21	Time:	8:30
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0034	mg/L	EPA 200.8	6/30/21	W SJM	A	
002	Site: DF11	Stagnant:	19.57 Hrs	Date Sampled:	6/16/21	Time:	8:35
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	6/30/21	W SJM	A	
003	Site: 1140	Stagnant:	18.18 Hrs	Date Sampled:	6/16/21	Time:	8:42
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0011	mg/L	EPA 200.8	6/30/21	W SJM	A	
004	Site: 1010	Stagnant:	18.75 Hrs	Date Sampled:	6/16/21	Time:	8:45
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	6/30/21	W SJM	A	
005	Site: 1150	Stagnant:	20.02 Hrs	Date Sampled:	6/16/21	Time:	8:50
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	6/30/21	W SJM	A	
006	Site: 1210 E	Stagnant:	18.28 Hrs	Date Sampled:	6/16/21	Time:	9:00
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	6/30/21	W SJM	A	
007	Site: 1240 L	Stagnant:	20.00 Hrs	Date Sampled:	6/16/21	Time:	9:03
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0022	mg/L	EPA 200.8	6/30/21	W SJM	A	
008	Site: 1240 R	Stagnant:	19.95 Hrs	Date Sampled:	6/16/21	Time:	9:06
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	6/30/21	W SJM	A	
009	Site: 1240 BR	Stagnant:	18.83 Hrs	Date Sampled:	6/16/21	Time:	9:10
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	6/30/21	W SJM	A	
010	Site: 1240 BL	Stagnant:	19.08 Hrs	Date Sampled:	6/16/21	Time:	9:08
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.

Laboratory Report

CLIENT:	Champlain Valley Edu Services	WORK ORDER:	2106-16955
PROJECT:	Lead in School Taps,CVES MineV	DATE RECEIVED:	6/16/21
Lead, Total	0.0035	mg/L	EPA 200.8
			6/30/21
			W SJM
			A

011	Site: 19	Stagnant:	18.53 Hrs	Date Sampled:	6/16/21	Time:	9:13
-----	----------	-----------	-----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0016	mg/L	EPA 200.8	6/30/21	W SJM	A	

012	Site: 1230	Stagnant:	19.25 Hrs	Date Sampled:	6/16/21	Time:	9:16
-----	------------	-----------	-----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	6/30/21	W SJM	A	

013	Site: DF2	Stagnant:	18.42 Hrs	Date Sampled:	6/16/21	Time:	9:23
-----	-----------	-----------	-----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	6/30/21	W SJM	A	

014	Site: DF3	Stagnant:	20.52 Hrs	Date Sampled:	6/16/21	Time:	9:20
-----	-----------	-----------	-----------	---------------	---------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	6/30/21	W SJM	A	

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY
Due Date: 30 Jun 21

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

**INCOMPLETE
PAPERWORK**

Client: CUES Mineville Account #: 200674 SAMPLE SUPPLY INFORMATION

Email Address: brooksajerry@CUES.org PWS # _____

Contact Person: Jerry Brooks Project Name: _____ Collection Address: _____

Phone: 518-561-0100 EXT 219 3T - Lead in Schools

PO # _____ City: _____ State: _____ Zip: _____

Champlain Valley Ed Serv Pag 1 of 2 Collector's Name: Jerry Brooks

SAMPLE MATRIX CODES		Compliance? Yes Initial Testing or Repeat Testing	Bottle Type / Volume	Matrix	Preservation	First Draw (X)	Flushed Line (X)	Total Lead	Analysis Requested:		Lab Use Sample #
DW=drinking water	SW=Surface Water								Water Last Used (Date / Time)	Sample #	
WW=waste water	SD=solid										
MW=monitoring well	SO=soil										
HW=hazardous waste	SL=sludge										
TURNAROUND TIME REQUESTED											
Standard (2-4 weeks)											
Sample ID / Collection Site	Date/Time										
1 <u>1080</u>	<u>8:30 6/16/21</u>		250mL, P	DW	*			X		<u>2:10 pm 6/16/21</u>	001
2 <u>DF-11</u>	<u>8:35 6/16/21</u>		250mL, P	DW	*			X		<u>1:01 p 6/16/21</u>	002
3 <u>1140</u>	<u>8:42 6/16/21</u>		250mL, P	DW	*			X		<u>2:31 p 6/16</u>	003
4 <u>1010</u>	<u>8:45 6/16/21</u>		250mL, P	DW	*			X		<u>2:00 p 6/16/21</u>	004
5 <u>1130</u>	<u>8:50 6/16/21</u>		250mL, P	DW	*			X		<u>12:49 p 6/15</u>	005
6 <u>1210 E</u>	<u>9:00 AM 6/16/21</u>		250mL, P	DW	*			X		<u>2:43 p 6/15</u>	006
7 <u>1840 L</u>	<u>9:03 6/16/21</u>		250mL, P	DW	*			X		<u>1:03 p 6/15</u>	007
8 <u>1240 K</u>	<u>9:06 6/16/21</u>		250mL, P	DW	*			X		<u>1:09 p 6/15</u>	008
9 <u>1240 BR</u>	<u>9:10 6/16/21</u>		250mL, P	DW	*			X		<u>2:20 6/15</u>	009
10 <u>1240 BL</u>	<u>9:08 6/16/21</u>		250mL, P	DW	*			X		<u>2:03 6/15</u>	010
11 <u>19</u>	<u>9:13 6/16</u>		250mL, P	DW	*			X		<u>2:41 6/15</u>	011
12 <u>1230</u>	<u>9:16 6/16</u>		250mL, P	DW	*			X		<u>2:01 6/15</u>	012

**INCOMPLETE
PAPERWORK**

SAMPLE RECEIPT (Lab Use Only)

Samples Intact? <u>yes</u>	Date <u>16 Jun 21</u>	Time <u>1252</u>	Sample Relinquished By (SIGN HERE) <u>[Signature]</u>	Samples Received By <u>[Signature]</u>
Filled to proper volume? <u>yes</u>				
# of Containers <u>14</u>				

2106-16955



Champlain Valley Edu Services
Lead in School Taps, CUES MineU

* Samples preserved with NHO3 to pH < 2 after receipt at the lab. 0930 am 6/18

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

OFFICE USE ONLY

Analysis Fee \$ X or A/R

Terms are net 30 days with an open, up to date account.

Payment Method Cash Check MC/Visa Money Order

Check, MO, Receipt # _____



Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: NES Account #: 200674 Collector's Name: Jerry Boyle

Page 2 of 2 Work Order # 2106-116955

Sample ID / Collection Site	Date/Time	Bottle	M a t r i x	Pres	1st Draw	Flushed Line	Lead, Total	Water Last Used (date/ Time)	Sample #
13 DF2	9:03 4/16/21	250mL, P	DW	*			X	2:58p 4/15/21	013
14 DF3	9:20 4/16	250mL, P	DW	*			X	12:49p 4/15	014
15		250mL, P	DW	*			X		015
16		250mL, P	DW	*			X		016
17		250mL, P	DW	*			X		017
18		250mL, P	DW	*			X		018
19		250mL, P	DW	*			X		019
20		250mL, P	DW	*			X		020
21		250mL, P	DW	*			X		021
22		250mL, P	DW	*			X		022
23		250mL, P	DW	*			X		023
24		250mL, P	DW	*			X		024

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client:

Account #:

Collector's Name:

Page 3 of

Work Order #

Sample ID / Collection Site	Date/Time	Bottle	Matrix	Pres	1st Draw	Flushed Line	Lead, Total	Water Last Used (date/Time)	Sample #
47		250mL, P	DW	*			X		047
48		250mL, P	DW	*			X		048
49		250mL, P	DW	*			X		049
50		250mL, P	DW	*			X		050
51		250mL, P	DW	*			X		051
52		250mL, P	DW	*			X		052
53		250mL, P	DW	*			X		053
54		250mL, P	DW	*			X		054
55		250mL, P	DW	*			X		055
56		250mL, P	DW	*			X		056
57		250mL, P	DW	*			X		057
58		250mL, P	DW	*			X		058