



### Laboratory Report

Champlain Valley Edu Services	200674
PO Box 455	
1585 Military Turnpike	
Plattsburgh, NY 12901	
Atten: Angela Jennette	

PROJECT: Lead in School Taps, Rev 1  
WORK ORDER: **2312-39995**  
DATE RECEIVED: December 27, 2023  
DATE REPORTED: January 18, 2024  
SAMPLER:

Enclosed please find the results of the analyses performed for the samples referenced on the attached chain of custody located at the end of this report.

The column labeled Lab/Tech in the accompanying report denotes the laboratory facility where the testing was performed and the technician who conducted the assay. A "W" designates the Williston, VT lab under NELAC certification ELAP 11263; "R" designates the Lebanon, NH facility under certification NH 2037 and "N" the Plattsburgh, NY lab under certification ELAP 11892. "Sub" indicates the testing was performed by a subcontracted laboratory. The accreditation status of the subcontracted lab is referenced in the corresponding NELAC and Qual fields.

This NELAC column also denotes the accreditation status of each laboratory for each reported parameter. "A" indicates the referenced laboratory is NELAC accredited for the parameter reported. "N" indicates the laboratory is not accredited. "U" indicates that NELAC does not offer accreditation for that parameter in that specific matrix. Test results denoted with an "A" meet all National Environmental Laboratory Accreditation Program requirements except where denoted by pertinent data qualifiers. Test results are representative of the samples as they were received at the laboratory.

Endyne, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose.

Reviewed by:

Christina A Lafountain  
Laboratory Director Plattsburgh, NY

### Laboratory Report

CLIENT: Champlain Valley Edu Services  
PROJECT: Lead in School Taps, Rev 1

WORK ORDER: 2312-39995  
DATE RECEIVED: 12/27/23

001	Site: 2090	Stagnant:	14.00 Hrs	Date Sampled:	12/27/23	Time:	7:00
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/3/24	W RSB	A	
002	Site: 2110	Stagnant:	13.92 Hrs	Date Sampled:	12/27/23	Time:	7:00
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0011	mg/L	EPA 200.8	1/3/24	W RSB	A	
003	Site: 3001	Stagnant:	14.02 Hrs	Date Sampled:	12/27/23	Time:	7:06
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0020	mg/L	EPA 200.8	1/3/24	W RSB	A	
004	Site: 1060	Stagnant:	14.18 Hrs	Date Sampled:	12/27/23	Time:	7:14
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0019	mg/L	EPA 200.8	1/3/24	W RSB	A	
005	Site: 1070 L - LOW VOLUME	Stagnant:	14.08 Hrs	Date Sampled:	12/27/23	Time:	7:11
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0019	mg/L	EPA 200.8	1/3/24	W RSB	A	AN1
006	Site: 1070 R	Stagnant:	14.08 Hrs	Date Sampled:	12/27/23	Time:	7:11
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0032	mg/L	EPA 200.8	1/3/24	W RSB	A	
007	Site: 1070 BM	Stagnant:	14.07 Hrs	Date Sampled:	12/27/23	Time:	7:11
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0042	mg/L	EPA 200.8	1/3/24	W RSB	A	
008	Site: 1070 M - LOW VOLUME	Stagnant:	14.08 Hrs	Date Sampled:	12/27/23	Time:	7:12
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0022	mg/L	EPA 200.8	1/3/24	W RSB	A	AN1
009	Site: 1040 R	Stagnant:	14.08 Hrs	Date Sampled:	12/27/23	Time:	7:15
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/3/24	W RSB	A	
010	Site: 1040 L	Stagnant:	14.08 Hrs	Date Sampled:	12/27/23	Time:	7:15
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>

### Laboratory Report

CLIENT: Champlain Valley Edu Services	WORK ORDER: <b>2312-39995</b>
PROJECT: Lead in School Taps, Rev 1	DATE RECEIVED: 12/27/23
Lead, Total < 0.0010 mg/L EPA 200.8	1/3/24 W RSB A

011	Site: 1040 M	Stagnant:	14.07 Hrs	Date Sampled:	12/27/23	Time: 7:14
-----	--------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/3/24	W RSB	A	

012	Site: 1040 B	Stagnant:	14.07 Hrs	Date Sampled:	12/27/23	Time: 7:14
-----	--------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/3/24	W RSB	A	

013	Site: 1050 (Right on bottle)	Stagnant:	14.13 Hrs	Date Sampled:	12/27/23	Time: 7:20
-----	------------------------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0056	mg/L	EPA 200.8	1/3/24	W RSB	A	

014	Site: 1020 - LOW VOLUME	Stagnant:	14.13 Hrs	Date Sampled:	12/27/23	Time: 7:20
-----	-------------------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/3/24	W RSB	A	AN1

015	Site: 1020 DL	Stagnant:	14.18 Hrs	Date Sampled:	12/27/23	Time: 7:23
-----	---------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/3/24	W RSB	A	

016	Site: 1020 DR	Stagnant:	14.12 Hrs	Date Sampled:	12/27/23	Time: 7:23
-----	---------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/3/24	W RSB	A	

017	Site: 1000 N	Stagnant:	14.15 Hrs	Date Sampled:	12/27/23	Time: 7:25
-----	--------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/3/24	W RSB	A	

018	Site: 1000	Stagnant:	14.13 Hrs	Date Sampled:	12/27/23	Time: 7:26
-----	------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/3/24	W RSB	A	

019	Site: CV-TEC Office	Stagnant:	14.08 Hrs	Date Sampled:	12/27/23	Time: 7:25
-----	---------------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/3/24	W RSB	A	

## Laboratory Report

CLIENT: Champlain Valley Edu Services  
PROJECT: Lead in School Taps, Rev 1

WORK ORDER: 2312-39995  
DATE RECEIVED: 12/27/23

020	Site: 1DF	Stagnant:	14.08 Hrs	Date Sampled:	12/27/23	Time:	7:26
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/3/24	W RSB	A	
021	Site: 3260	Stagnant:	14.02 Hrs	Date Sampled:	12/27/23	Time:	7:27
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/3/24	W RSB	A	
022	Site: 3260 K	Stagnant:	14.12 Hrs	Date Sampled:	12/27/23	Time:	7:27
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/3/24	W RSB	A	
023	Site: 3070 K	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time:	7:30
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0047	mg/L	EPA 200.8	1/3/24	W RSB	A	
024	Site: 3070 1	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time:	7:30
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0028	mg/L	EPA 200.8	1/3/24	W RSB	A	
025	Site: 3250 - LOW VOLUME	Stagnant:	13.97 Hrs	Date Sampled:	12/27/23	Time:	7:31
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/3/24	W RSB	A	AN1
026	Site: 3070	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time:	7:30
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0023	mg/L	EPA 200.8	1/3/24	W RSB	A	
027	Site: 3080	Stagnant:	13.97 Hrs	Date Sampled:	12/27/23	Time:	7:33
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0019	mg/L	EPA 200.8	1/3/24	W RSB	A	
028	Site: 3230	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time:	7:35
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0057	mg/L	EPA 200.8	1/3/24	W RSB	A	
029	Site: 3231	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time:	7:35
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.

### Laboratory Report

CLIENT: Champlain Valley Edu Services	WORK ORDER: <b>2312-39995</b>
PROJECT: Lead in School Taps, Rev 1	DATE RECEIVED: 12/27/23
Lead, Total 0.0024 mg/L EPA 200.8	1/4/24 W RSB A

030 Site: 3100-1	Stagnant:	13.97 Hrs	Date Sampled:	12/27/23	Time: 7:36
------------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0011	mg/L	EPA 200.8	1/4/24	W RSB	A	

031 Site: 3100-2	Stagnant:	13.97 Hrs	Date Sampled:	12/27/23	Time: 7:36
------------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0014	mg/L	EPA 200.8	1/4/24	W RSB	A	

032 Site: 3212	Stagnant:	13.97 Hrs	Date Sampled:	12/27/23	Time: 7:37
----------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0015	mg/L	EPA 200.8	1/4/24	W RSB	A	

033 Site: 3200 - LOW VOLUME	Stagnant:	13.97 Hrs	Date Sampled:	12/27/23	Time: 7:37
-----------------------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/4/24	W RSB	A	AN1

034 Site: 3110	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time: 7:40
----------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/4/24	W RSB	A	

035 Site: 3190	Stagnant:	13.97 Hrs	Date Sampled:	12/27/23	Time: 7:37
----------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/4/24	W RSB	A	

036 Site: 3130	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time: 7:38
----------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0044	mg/L	EPA 200.8	1/4/24	W RSB	A	

037 Site: DF 2 - LOW VOLUME	Stagnant:	14.07 Hrs	Date Sampled:	12/27/23	Time: 7:46
-----------------------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/4/24	W RSB	A	AN1

038 Site: 3140	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time: 7:44
----------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0031	mg/L	EPA 200.8	1/4/24	W RSB	A	

## Laboratory Report

CLIENT: Champlain Valley Edu Services  
PROJECT: Lead in School Taps, Rev 1

WORK ORDER: 2312-39995  
DATE RECEIVED: 12/27/23

Site	Stagnant:		Date Sampled:	Time:			
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
039 Site: 3150	14.00 Hrs		12/27/23	7:45			
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/4/24	W RSB	A	
040 Site: 4450	14.02 Hrs		12/27/23	7:48			
Lead, Total	0.0012	mg/L	EPA 200.8	1/4/24	W RSB	A	
041 Site: 4420	14.03 Hrs		12/27/23	7:49			
Lead, Total	0.0015	mg/L	EPA 200.8	1/4/24	W RSB	A	
042 Site: 4410	14.00 Hrs		12/27/23	7:49			
Lead, Total	0.0016	mg/L	EPA 200.8	1/4/24	W RSB	A	
043 Site: 4460 - LOW VOLUME	14.00 Hrs		12/27/23	7:49			
Lead, Total	0.0018	mg/L	EPA 200.8	1/4/24	W RSB	A	AN1
044 Site: 4480	13.98 Hrs		12/27/23	7:50			
Lead, Total	0.0023	mg/L	EPA 200.8	1/4/24	W RSB	A	
045 Site: 4390	13.98 Hrs		12/27/23	7:50			
Lead, Total	0.0031	mg/L	EPA 200.8	1/4/24	W RSB	A	
046 Site: 4380 (bottle says 3380) LOW VOL	13.98 Hrs		12/27/23	7:50			
Lead, Total	0.0025	mg/L	EPA 200.8	1/4/24	W RSB	A	AN1
047 Site: Speech	13.98 Hrs		12/27/23	7:50			
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/4/24	W RSB	A	
048 Site: 4350	14.00 Hrs		12/27/23	7:52			
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.

### Laboratory Report

CLIENT: Champlain Valley Edu Services	WORK ORDER: <b>2312-39995</b>
PROJECT: Lead in School Taps, Rev 1	DATE RECEIVED: 12/27/23
Lead, Total 0.0019 mg/L EPA 200.8	1/4/24 W RSB A

049	Site: 4330	Stagnant: 14.00 Hrs	Date Sampled: 12/27/23	Time: 7:53
-----	------------	---------------------	------------------------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0023	mg/L	EPA 200.8	1/4/24	W RSB	A	

050	Site: 4320	Stagnant: 14.00 Hrs	Date Sampled: 12/27/23	Time: 7:53
-----	------------	---------------------	------------------------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0013	mg/L	EPA 200.8	1/5/24	W RSB	A	

051	Site: 4300 - LOW VOLUME	Stagnant: 14.00 Hrs	Date Sampled: 12/27/23	Time: 7:54
-----	-------------------------	---------------------	------------------------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0020	mg/L	EPA 200.8	1/5/24	W RSB	A	AN1

052	Site: DF-3	Stagnant: 13.98 Hrs	Date Sampled: 12/27/23	Time: 7:55
-----	------------	---------------------	------------------------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	

053	Site: 4006	Stagnant: 13.98 Hrs	Date Sampled: 12/27/23	Time: 7:55
-----	------------	---------------------	------------------------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0012	mg/L	EPA 200.8	1/5/24	W RSB	A	

054	Site: 4280	Stagnant: 14.00 Hrs	Date Sampled: 12/27/23	Time: 7:56
-----	------------	---------------------	------------------------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0014	mg/L	EPA 200.8	1/5/24	W RSB	A	

055	Site: 4250	Stagnant: 14.00 Hrs	Date Sampled: 12/27/23	Time: 7:57
-----	------------	---------------------	------------------------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0023	mg/L	EPA 200.8	1/5/24	W RSB	A	

056	Site: 4010	Stagnant: 14.00 Hrs	Date Sampled: 12/27/23	Time: 7:57
-----	------------	---------------------	------------------------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0022	mg/L	EPA 200.8	1/5/24	W RSB	A	

057	Site: 4026 - LOW VOLUME	Stagnant: 13.98 Hrs	Date Sampled: 12/27/23	Time: 7:58
-----	-------------------------	---------------------	------------------------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0017	mg/L	EPA 200.8	1/5/24	W RSB	A	AN1

**Laboratory Report**

CLIENT: Champlain Valley Edu Services  
 PROJECT: Lead in School Taps, Rev 1

WORK ORDER: 2312-39995  
 DATE RECEIVED: 12/27/23

058	Site: 4210	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time:	7:58
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0017	mg/L	EPA 200.8	1/5/24	W RSB	A	
059	Site: 4030	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time:	7:59
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0016	mg/L	EPA 200.8	1/5/24	W RSB	A	
060	Site: 4200	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time:	7:59
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0026	mg/L	EPA 200.8	1/5/24	W RSB	A	
061	Site: 4050	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time:	8:00
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0024	mg/L	EPA 200.8	1/5/24	W RSB	A	
062	Site: 4190	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time:	8:00
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0029	mg/L	EPA 200.8	1/5/24	W RSB	A	
063	Site: 4180	Stagnant:	13.97 Hrs	Date Sampled:	12/27/23	Time:	8:00
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	
064	Site: 4170	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time:	8:01
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0025	mg/L	EPA 200.8	1/5/24	W RSB	A	
065	Site: 4150	Stagnant:	13.97 Hrs	Date Sampled:	12/27/23	Time:	8:02
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0018	mg/L	EPA 200.8	1/5/24	W RSB	A	
066	Site: 4160	Stagnant:	13.97 Hrs	Date Sampled:	12/27/23	Time:	8:02
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0014	mg/L	EPA 200.8	1/5/24	W RSB	A	
067	Site: 4060	Stagnant:	13.97 Hrs	Date Sampled:	12/27/23	Time:	8:03
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.



### Laboratory Report

CLIENT: Champlain Valley Edu Services	WORK ORDER: <b>2312-39995</b>
PROJECT: Lead in School Taps, Rev 1	DATE RECEIVED: 12/27/23
Lead, Total 0.0035 mg/L EPA 200.8	1/5/24 W RSB A

068 Site: 4070-S1	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time: 8:06
-------------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	

069 Site: 4070-S-2	Stagnant:	13.98 Hrs	Date Sampled:	12/27/23	Time: 8:06
--------------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	

070 Site: 4070-P-1	Stagnant:	13.95 Hrs	Date Sampled:	12/27/23	Time: 8:07
--------------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	

071 Site: 4070-P2	Stagnant:	13.95 Hrs	Date Sampled:	12/27/23	Time: 8:07
-------------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	

072 Site: 4070-P3 - LOW VOLUME	Stagnant:	13.95 Hrs	Date Sampled:	12/27/23	Time: 8:07
--------------------------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	AN1

073 Site: D4	Stagnant:	14.00 Hrs	Date Sampled:	12/27/23	Time: 8:10
--------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	

074 Site: M 1080	Stagnant:	18.58 Hrs	Date Sampled:	12/27/23	Time: 9:34
------------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0056	mg/L	EPA 200.8	1/5/24	W RSB	A	

075 Site: M DF1	Stagnant:	18.58 Hrs	Date Sampled:	12/27/23	Time: 9:35
-----------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	

076 Site: M 1142	Stagnant:	18.57 Hrs	Date Sampled:	12/27/23	Time: 9:36
------------------	-----------	-----------	---------------	----------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0012	mg/L	EPA 200.8	1/5/24	W RSB	A	

## Laboratory Report

CLIENT: Champlain Valley Edu Services  
PROJECT: Lead in School Taps, Rev 1

WORK ORDER: 2312-39995  
DATE RECEIVED: 12/27/23

077	Site: M 1010	Stagnant:	18.55 Hrs	Date Sampled:	12/27/23	Time:	9:38
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	
078	Site: M 1150	Stagnant:	18.55 Hrs	Date Sampled:	12/27/23	Time:	9:39
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	
079	Site: M DF2	Stagnant:	18.52 Hrs	Date Sampled:	12/27/23	Time:	9:41
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	
080	Site: M DF3	Stagnant:	18.50 Hrs	Date Sampled:	12/27/23	Time:	9:43
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	
081	Site: M 1240L	Stagnant:	18.53 Hrs	Date Sampled:	12/27/23	Time:	9:45
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	
082	Site: M 1240R	Stagnant:	18.45 Hrs	Date Sampled:	12/27/23	Time:	9:45
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0016	mg/L	EPA 200.8	1/5/24	W RSB	A	
083	Site: M 1230	Stagnant:	18.43 Hrs	Date Sampled:	12/27/23	Time:	9:47
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	
084	Site: L DFN	Stagnant:	16.45 Hrs	Date Sampled:	12/27/23	Time:	8:57
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	
085	Site: L Confren Kitchen - LOW VOLUME	Stagnant:	17.92 Hrs	Date Sampled:	12/27/23	Time:	10:26
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	AN1
086	Site: L DFB - LOW VOLUME	Stagnant:	17.80 Hrs	Date Sampled:	12/27/23	Time:	10:24
Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.

**Laboratory Report**

CLIENT:	Champlain Valley Edu Services	WORK ORDER:	<b>2312-39995</b>
PROJECT:	Lead in School Taps, Rev 1	DATE RECEIVED:	12/27/23
Lead, Total	< 0.0010	mg/L	EPA 200.8
			1/5/24
			W RSB
			A
			AN1

087	Site: L DFC	Stagnant:	17.83 Hrs	Date Sampled:	12/27/23	Time:	10:25
-----	-------------	-----------	-----------	---------------	----------	-------	-------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	< 0.0010	mg/L	EPA 200.8	1/5/24	W RSB	A	

088	Site: 1050 (Left on bottle)	Stagnant:	0.00 Hrs	Date Sampled:	12/27/23	Time:	7:20
-----	-----------------------------	-----------	----------	---------------	----------	-------	------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Lead, Total	0.0069	mg/L	EPA 200.8	1/5/24	W RSB	A	

Report Summary of Qualifiers and Notes

REV 1: Report reinstated to add the following qualifier to samples received with low volume:

AN1: Sample volume submitted not adequate for test method. Client requests that samples be analyzed with low volume.

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.

# Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road  
Plattsburgh, NY 12903  
Phone (518)563-1720

Fax (518)563-0052  
info@endynelabs.com  
ELAP #11892

Client: **CUES** *Champlain Valley Edu Services* Account #: \_\_\_\_\_ Collector's Name: **Jerry Brooks**

Page 4 of \_\_\_\_\_ Work Order # \_\_\_\_\_

Sample ID / Collection Site	Date/Time	Bottle	M a t r i x	Pres	1st Draw	Flushed Line	Lead, Total	Water Last Used (date/Time)	Sample #
81 4070-S-2	12/27 8:06 AM	250mL, P	DW	*	X		X	12/26 6:07 PM	081
82 4070-P-1	8:07	250mL, P	DW	*	X		X	6:10 PM	082
83 4070-P2	8:07	250mL, P	DW	*	X		X	6:10 PM	083
*2 84 4070-P3	8:07	250mL, P	DW	*	X		X	6:10 PM	084
85 D4	8:10	250mL, P	DW	*	X		X	6:10 PM	085
86		250mL, P	DW	*			X		<del>086</del>
87		250mL, P	DW	*			X		<del>087</del>
88		250mL, P	DW	*			X		<del>088</del>
89 M 1080	9:34	250mL, P	DW	*	X		X	2:59 PM	089
90 M DF1	9:35	250mL, P	DW	*	X		X	3:00 PM	090
91 M 1142	9:36	250mL, P	DW	*	X		X	3:02 PM	091
92 M 1010	9:38	250mL, P	DW	*	X		X	3:05 PM	092
93 M 1150	9:39	250mL, P	DW	*	X		X	3:06 PM	093
94 M DF2	9:41	250mL, P	DW	*	X		X	3:10 PM	094
95 M DF3	9:43	250mL, P	DW	*	X		X	3:13 PM	095
96 M 1240 L	9:45	250mL, P	DW	*	X		X	3:18 PM	096
97 M 1240 R	9:45	250mL, P	DW	*	X		X	3:18 PM	097
98 M 1230	9:47	250mL, P	DW	*	X		X	3:21 PM	098
99		250mL, P	DW	*			X		<del>099</del>
100		250mL, P	DW	*			X		<del>100</del>
101		250mL, P	DW	*			X		<del>101</del>
102		250mL, P	DW	*			X		<del>102</del>
103 L DFN	9:57 AM	250mL, P	DW	*			X	4:30 PM	103
*2 104 L Cafren Kitchsn	10:26	250mL, P	DW	*			X	4:31 PM	104
105 L DFB #2	10:24	250mL, P	DW	*			X	4:30 PM	105
106 L DFC	10:25	250mL, P	DW	*			X	4:35 PM	106
107		250mL, P	DW	*					
108		250mL, P	DW	*					
109		250mL, P	DW	*					
110		250mL, P	DW	*					
111		250mL, P	DW	*					
112		250mL, P	DW	*					
113 not recorded on coc @		250mL, P	DW	*					
114 1050 Left	12/27/23 0720	250mL, P	DW	*		X		??	144

\*2 bottle not filled enough

2312-39995



Champlain Valley Edu Services  
Lead in School Taps.

Rec'd 27 Dec 23 @ 1312 (Gr) \*1 bottle says "3380" (20)

069  
070  
071  
072 \*2  
073  
—  
—  
—  
074  
075  
076  
077  
078  
079  
080  
081  
082  
083  
—  
—  
—  
084  
085 \*2  
086  
087

# Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road  
Plattsburgh, NY 12903  
Phone (518)563-1720

Fax (518)563-0052  
info@endynelabs.com  
ELAP #11892

Client: *CUES Champlain Valley AG SERVICES*

Account #:

Collector's Name: *Jerry Brooks*

Page *1* of *4*

Work Order #

Sample ID / Collection Site	Date/Time	Bottle	Matrix	Pres	1st Draw	Flushed Line	Lead, Total	12/26 Water Last Used (date/ Time)	Sample #
13 2090	7 AM	250mL, P	DW	*	X		X	5 PM	013
14 2110	7 A	250mL, P	DW	*	X		X	5:05	014
15 3001	7:06	250mL, P	DW	*	X		X	5:05	015
16 1060	7:14	250mL, P	DW	*	X		X	5:03	016
*2 17 1070 L	7:11	250mL, P	DW	*	X		X	5:06	017
18 1070 R	7:11	250mL, P	DW	*	X		X	5:06	018
19 1070 BM	7:11	250mL, P	DW	*	X		X	5:07	019
*2 20 1070 M	7:12	250mL, P	DW	*	X		X	5:07	020
21 1040 R	7:15	250mL, P	DW	*	X		X	5:10	021
22 1040 L	7:15	250mL, P	DW	*	X		X	5:10	022
23 1040 M	7:14	250mL, P	DW	*	X		X	5:10	023
24 1040 B	7:14	250mL, P	DW	*	X		X	5:10	024
25 1050	7:20	250mL, P	DW	*	X		X	5:12	025
*2 26 1020	7:22	250mL, P	DW	*	X		X	5:15	026
27 1020 DL	7:23	250mL, P	DW	*	X		X	5:16	027
28 1020 DR	7:23	250mL, P	DW	*	X		X	5:16	028
29 1000 N	7:25	250mL, P	DW	*	X		X	5:18	029
30 1000	7:26	250mL, P	DW	*	X		X	5:18	030
31 CU-TEC office	7:25	250mL, P	DW	*	X		X	5:19	031
32 1 DF	7:26	250mL, P	DW	*	X		X	5:20	032
33 3260	7:27	250mL, P	DW	*	X		X	5:21	033
34 3260 K	7:27	250mL, P	DW	*	X		X	5:26	034
35 3070 K	7:30	250mL, P	DW	*	X		X	5:20	035
36 3070 I	7:30	250mL, P	DW	*	X		X	5:31	036
*2 37 3250 <del>3070</del>	7:31	250mL, P	DW	*	X		X	5:31	037
38 3070	7:30	250mL, P	DW	*	X		X	5:37	038
39 3080	7:33	250mL, P	DW	*	X		X	5:31	039
40 3230	7:35	250mL, P	DW	*	X		X	5:35	040
41 3231	7:35	250mL, P	DW	*	X		X	5:36	041
42 3100-1	7:36	250mL, P	DW	*	X		X	5:36	042
43 3100-2	7:36	250mL, P	DW	*	X		X	5:38	043
44 3212	7:37	250mL, P	DW	*	X		X	5:38	044
*2 45 3200	7:37	250mL, P	DW	*	X		X	5:39	045
46 3110	7:40	250mL, P	DW	*	X		X	5:39	046
								5:41	046

\* samples plus to pH < 2 with HNO<sub>3</sub> @ lab: 1000 on 28 Dec 23, by Andrew B. (8)

# Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road  
Plattsburgh, NY 12903  
Phone (518)563-1720

Fax (518)563-0052  
info@endynelabs.com  
ELAP #11892

Client: **CUES Champion's Valley  
ed services**

Account #:

Collector's Name: **Jerry Brooks**

Page 3 of

Work Order #

Sample ID / Collection Site	Date/Time	Bottle	M a t r i x	Pres	1st Draw	Flushed Line	Lead, Total	12/26		
								Water Last Used (date/Time)	Sample #	
47 3190	12/27 7:37	250mL, P	DW	*	X		X	5:39	047	035
48 3130	7:38	250mL, P	DW	*	X		X	5:41	048	036
*2 49 DF2	7:46	250mL, P	DW	*	X		X	5:42	049	037 *2
50 3140	7:44	250mL, P	DW	*	X		X	5:45	050	038
51 3150	7:45	250mL, P	DW	*	X		X	5:45	051	039
52 4450	7:48	250mL, P	DW	*	X		X	5:47	052	040
53 4420	7:49	250mL, P	DW	*	X		X	5:47	053	041
*2 54 4410	7:49	250mL, P	DW	*	X		X	5:49	054	042
55 4460	7:49	250mL, P	DW	*	X		X	5:49	055	043 *2
56 4480	7:50	250mL, P	DW	*	X		X	5:51	056	044
57 4390	7:50	250mL, P	DW	*	X		X	5:51	057	045
*2 58 4380	7:50	250mL, P	DW	*	X		X	5:51	058	046 *2
59 speed	7:50	250mL, P	DW	*	X		X	5:51	059	047 *2
60 4350	7:50	250mL, P	DW	*	X		X	5:52	060	048
61 4330	7:53	250mL, P	DW	*	X		X	5:53	061	049
62 4320	7:53	250mL, P	DW	*	X		X	5:53	062	050
*2 63 4300	7:54	250mL, P	DW	*	X		X	5:54	063	051 *2
64 DF-3	7:55	250mL, P	DW	*	X		X	5:56	064	052
65 4006	7:55	250mL, P	DW	*	X		X	5:56	065	053
66 4080	7:56	250mL, P	DW	*	X		X	5:56	066	054
67 4050	7:57	250mL, P	DW	*	X		X	5:57	067	055
68 4010	7:57	250mL, P	DW	*	X		X	5:57	068	056
*2 69 4026	7:58	250mL, P	DW	*	X		X	5:59	069	057 *2
70 4210	7:58	250mL, P	DW	*	X		X	5:59	070	058
71 4030	7:59	250mL, P	DW	*	X		X	6:00	071	059
72 4200	7:59	250mL, P	DW	*	X		X	6:00	072	060
73 4050	8:00	250mL, P	DW	*	X		X	6:01	073	061
74 4190	8:00	250mL, P	DW	*	X		X	6:01	074	062
75 4180	8:00	250mL, P	DW	*	X		X	6:02	075	063
76 4170	8:01	250mL, P	DW	*	X		X	6:02	076	064
77 4150	8:02	250mL, P	DW	*	X		X	6:04	077	065
78 4160	8:02	250mL, P	DW	*	X		X	6:04	078	066
79 4060	8:03	250mL, P	DW	*	X		X	6:05	079	067
80 4070-51	8:06	250mL, P	DW	*	X		X	6:07	080	068

# Endyne, Inc

315 New York Road  
Plattsburgh, NY 12903

(518) 563-1720  
Fax: (518) 563-0052

## Sampling Instructions – Lead Sampling in Schools

Refer to the current NYS DOH Lead in Schools Guidance Manual for additional details. A sample must be collected after water has been sitting in the pipes for an extended period of time. A minimum 8-hour period during which there is no water use (and maximum of 18 hours) must be achieved prior to drawing the water for the sample. Due to this requirement, it is recommended that the sample be collected before the facility is open and before any water is used that day from Any tap. The collection procedure is described below:

1. Wait a minimum eight (8) hour period during which there is no water use to be sure stagnant conditions exist (this includes toilets). Collect all water samples before the facility is open for the day and before any water is used. The water should be sitting stagnant in the pipes for at least 8 hours, but not longer than 18 hours (unless it's normal for those sites to be unused for longer periods of time).
2. Do not remove the screen or tip of the tap that you are sampling from.
3. Follow the sampling plan. Begin sampling at the outlet closest to the point of entry and continue toward the outlet farthest from the point of entry. If there are multiple floors, sample from the bottom floor and continue up.
4. Place the bottle below the faucet and open the COLD water tap at the same rate that would be used to fill a glass of water. Make sure all water coming from the tap goes into the bottle. Fill the bottle to exactly the 250mL fill line that is marked on the bottle. There MUST be at least 250mL for the sample to be analyzed, but the bottle should not be filled much past that line. Do NOT overflow the bottle or pour any sample volume out! Tightly cap the sample bottle.
5. Label the bottle clearly and make sure the same ID is used on this form and the Chain of Custody (COC). Fill out the information at the bottom of this form completely. Contact your water operator or the lab if you have any questions.
6. Samples MUST be delivered to the lab within 5 days of collection. They do not need to be on ice.

Water Last Used: Date: 12/21/23 Time: 3:00 PM to 5:00 PM


Sample Collected on: Date: 12/27/23 Time: 6:30 AM to 10:30 AM

This sample is a (check one):  First Draw  Flushed Line (\_\_\_ min)  Follow-Up

Sampling Site ID / Site Number: \_\_\_\_\_

Maintenance since last sampling: Yes /  No If Yes then what: \_\_\_\_\_

**I attest that I followed the instructions on this sheet and that all of the information on this sheet is true and complete to the best of my knowledge:**

 Jerry L Braker 12/27/23  
(Signature of person taking the sample) (Print) (Date)

**Re: [External]Lead in School Samples Submitted by Jerry Brooks on 27-Dec-23**


Smith, Tom &lt;smith\_tom@cves.org&gt;

Thu 1/11/2024 10:26 AM

To: Amber St John &lt;astjohn@endynelabs.com&gt;

Cc: Jennette, Angela &lt;Jennette\_Angela@cves.org&gt;

Hi Amber,

A handwritten note in blue ink, enclosed in a hand-drawn cloud shape. The text reads "NO #2312-39995".

Per our conversation a little while ago, I spoke with Jerry regarding sample 1050 Left. you indicated that there was no time/date the water was last known to be used. After speaking with Jerry and looking at the sample list we were able to determine that the last use time for this is the same as 1050 Right. That time was 5:12pm on 12/26 for a total sit time of 14:13.

I looked at the low fill samples and they all were tested and were well under the 5ppb limit. So we should be ok in that regard.

I also spoke to Jerry about the missing samples/first page of the Chain of Custody. He and Chris did discuss this when he brought in the samples. They were missing the front page of the COC when they got the bottles & paperwork. Jerry said that he offered to fill out the front page while dropping off the samples and was told that it wouldn't be necessary. He did not have any more samples that needed to be submitted. He did intentionally order about 20 extra bottles as he was expecting to have to re-test a few outlets for being over the 5ppb limit and he wanted to have everything on site and ready to go, especially since one of our campuses is an hour away.

Please let me know if there is anything that we need to do on our end. I'm going to follow up one last time to ensure that our samples that were low are still sufficient, but unless you hear back from me stating otherwise, please assume that no further action is necessary.

I'll follow up with St. Regis Falls momentarily on their low samples as well and get back to you on that.

Thank you again for your assistance on these matters,

Tom Smith

---

**From:** Amber St John <astjohn@endynelabs.com>**Sent:** Wednesday, January 3, 2024 11:47 AM**To:** Smith, Tom <smith\_tom@cves.org>; Jennette, Angela <Jennette\_Angela@cves.org>**Subject:** [External]Lead in School Samples Submitted by Jerry Brooks on 27-Dec-23

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe. Please forward this email to [cvesnetadmin@cves.org](mailto:cvesnetadmin@cves.org) if you believe this email is suspicious.

Good morning. The following samples submitted by Jerry Brooks on 27-Dec-23 were not filled to the 250mL mark required by the test method for Lead in Schools:

1070 L, 1070 M, 1020, 3250, 3200, DF2, 4460, 4380 (labelled as 3380 on bottle), 4300, 4026, 4070-P3, L Confirm Kitchen, L DFB



Also, the following ID was not listed on the COC at all and was added at the lab: 1050 Left, Sampled 12/27/23 @ 0720 per bottle label, no date/time water was last used known. Chris indicated that there were more samples to be received from this location as they were on the first page of the COC that was not submitted with the samples. I have attached a copy of the COC for your reference.

Thank you and have a good day,

Amber A. St. John  
Lab Technician - Chemical Hygiene Coordinator/ Safety Officer  
Endyne - Plattsburgh  
315 New York Road, Ste 85  
Plattsburgh, NY 12903  
P: 518-563-1720  
F: 518-563-0052

---

This email has been scanned for spam and viruses by Proofpoint Essentials. Click [here](#) to report this email as spam.